

CERTIFICATE OF COMPLIANCE

Certificate Number 20160119-EX26915
Report Reference EX26915-20160119
Issue Date 2016-JANUARY-19

Issued to: ARCELORMITTAL TUBULAR PRODUCTS OSTRAVA A.S.
Vratimovska 689
707 02 Ostrava - Kuncice CZECH REPUBLIC

**This is to certify that
representative samples of**

METALLIC SPRINKLER PIPE

Schedule 40 steel sprinkler pipe for wet, dry, preaction and deluge type sprinkler systems with unthreaded ends intended to be joined by welding or Listed Rubber Gasketed Fittings when installed in accordance with the fitting manufacturer's specifications.

Schedule 40 steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, and 10 inch sizes

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852, Metallic Sprinkler Pipe for Fire Protection Service; ULC/ORD C199S, Light Wall Steel Pipes for Sprinkler Systems for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/certifications/>

